

RIVERSIDE COUNTY FLOOD CONTROL AND WATER CONSERVATION DISTRICT

ENCROACHMENT PERMIT

City of Riverside Public Utilities
Electric Light and Water Departments
3854 Mulberry Street
Riverside, California

Riverside, California

July 19 19, 60

In compliance with your request of June 29, 19 60
and subject to all the terms, conditions and restrictions written below or printed as general
or special provisions on any part of this form

PERMISSION IS HEREBY GRANTED TO City of Riverside, Public Utilities
Department, to install 66 KV power line adjacent to the easterly right of
way line of east levee of Riverside Levees, Santa Ana River, in accordance
with Drawing T5-11835, sheets 1 through 10 as revised, prepared by City of
Riverside, Public Utilities Department. It is understood a minimum clearance
of 20 feet between toe of slope of existing levee and any construction shall
be maintained.

This permit is to be strictly construed and no work other than that specifically men-
tioned above is authorized hereby. Performance of the work shall be deemed to be accept-
ance by the Permittee of all terms and conditions of this permit.

This permit shall be void unless work herein contemplated shall have been completed
before January 1, 19 61

J.W. Bryant, Chief Engineer

By