
955
945
965
955
7
8
9
10
11
12
13
14
15
16
17
PROPOSED TOP OF CURB
H.G.L.
EX. FIRE HYDRANT LATERAL
EX. WATER METER SERVICE
EX. AIR VALVE LATERAL
EX. 6" BLOW-OFF LATERAL ABAND. (PRIV. LINE CRUSH IN PLACE
TEL. CABLE TO BE RELOCATED (BY OTHERS)
GAS LINE
SF = 0.5 1/2%
SF = 1.68%
Q = 66.6 cfs
V = 11.2 fps
Q MAX = 66.6 cfs (PER C/R PLAN Nº D-492)
INSTALL 107.44 L.F. OF 42" Ø C.I.P.P. OR R.C.P. @ 1.20% (1000-D)
INSTALL 492.07 534.51 L.F. OF 42" Ø C.I.P.P. OR R.C.P. @ 1.20 % (1000-D)
INSTALL 322.63 L.F. OF 33" Ø C.I.P.P. OR R.C.P. @ 2.32% (1750-D)
Q = 72.1 cfs
V = 7.5 fps
CONTRACTOR IS TO VERIFY PROPOSED STORM DRAIN ELEVATION PRIOR TO CONSTRUCTION
NOTE : THE STORM DRAIN PIPING SHOWN ON SHEET IS TO BE BUILT CONCURRENTLY OR AFTER THAT SHOWN ON C/R PLAN Nº D-454
CONNECTION TO R.C.F.C.D. PER C/R PLAN Nº D-454
JOIN PROP. S.D. PER C/R PLAN Nº D-454
JOIN EXIST. S.D. PER C/R PLAN Nº D-492
REMOVE & RELAY APPROX. 94'± OF EXIST. 33" Ø R.C.P.
CONST. M.H. #3 (E Z PER C/R STD. NO. 419)
CONST. M.H. #2 PER C/R STD. NO. 420
JUNCTION STRUCTURE B PER C/R STD. NO. 421
8' C.B. PER C/R STD. 405
8' C.B. PER C/R STD. 405 (V = 2.76')
STA. 16+04.70 JOIN EXIST. S.D. PER C/R PLAN Nº D-492
STA. 14+10.15 E.C.
STA. 13+99.47 B.C.
STA. 12+82.07 JUNCTION STRUCTURE B PER C/R STD. NO. 421
STA. 11+94.07 (1" = 2.96')
STA. 7+42.56 JOIN PROP. S.D. PER C/R PLAN Nº D-454
(47.87' R) PROP. 24" R.C.P. (C/R PLAN Nº D-454)
(0.6%)
(5.2% +/-)
(6.5% +/-)
(2.2% +/-)
(6.30) H.G.L.
(42.28' +/-)
(42.28' +/-)
(42.87' +/-)
(42.87' +/-)
(42.94' +/-)
(42.94' +/-)
(42.94